

SECTION 6

6.09 CHECK VALVES:

A check valve permits flow in one direction only, closing when the flow stops so that no reversal can occur. Check valves shall conform to MS-6. They shall be used where shown in typical meter installation. They are otherwise prohibited unless specifically approved by Denver Water. Check valves shall be located in concrete manholes of the same specifications as required for PRV manhole installations as shown on Standard Drawings 41, 42, 43, and 44.